

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0328:163 Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Potter, 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Models AH-24R and AH-24W audible devices; Models ASH24-153075R, ASH24-153075W, ASH24-75110R and ASH24-75110W audible/visual devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC
All strobes rated at 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and audibility ratings and UL label.

APPROVAL: Listed as horns or horn/strobes for use with separately listed compatible fire alarm control units. Models with strobe are suitable for the hearing impaired applications and intended for indoor use only.

Units can generate a distinctive three pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition.

XLF: 7135-0587:118

03-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager